

SCHEDULE-V

Decision on IEE

1. **Name, address of proponent:** Mr. Said Naeem,
Owner of Retail Outlet of Askar-1 Oil Service, Qatar Petroleum (Proposed name) Jabab Road, Tehsil Dargai, District Malakand.
Contact No. 0334-9336238
2. **Description of project.** The project namely "Askar-1 Oil Service, Qatar Petroleum (Proposed name) Jaban Road, Tehsil Dargai, District Malakand is located Near village Dargai, District Malakand. Total area of the project is 42 kanals. The project shall involve the setting up of 2 fuel dispensing pumps, 1 for petrol and 1 for diesel. 2 tanks shall be buried underground at a depth of 3.5 meters with a capacity of 25000, liters each for petrol and diesel. All the pumps shall operate under a canopy (shed). A localized drainage system shall be in place to capture fugitive leak fuel which will be directed to an oil separator for sound environmental stewardship.
3. **Location of Project.** The Project is located in District Malakand.
4. **GPS Coordinates:**
N 34.512150
E 71.899773
5. **Date of Filing of IEE.** 21/01/2021

6. After careful review of the Initial Environmental Examination (IEE) report of project "**Askar-1 Oil Service, Qatar Petroleum (Proposed name), Jaban Road, Tehsil Dargai, District Malakand**" followed by queries, comments, clarifications/replies by the proponent, Environmental Protection Agency (EPA), Government of Khyber Pakhtunkhwa has decided to accord its approval with the guidelines issued by Khyber Pakhtunkhwa Environmental Protection Act, 2014 and IEE/EIA Regulations, 2000, on IEE Report subject to the following terms and conditions:

- a) The proponent shall adopt all precautionary and mitigation measures identified in IEE Report, explanation/clarification submitted to this Agency in response to various observations/queries raised during presentation as well as any un-anticipated impacts during the construction and operation phase of project.
- b) The site was visited by Mr. Ibrar Ahmad, Assistant Director and Mr.

Copy

wherein it was reported that no School, College, Mosque, Hospital were found within 100m radius.

- c) The Proponent shall ensure the compliance and implementation of the National Environmental Quality Standard (NEQS) for Ambient Air, Noise, Water and gaseous emission during construction and Operation phase of the Project.
- d) The safety and emergency measures as per Petroleum Rules shall be carried out in the premises of the project area e.g. emergency exits, fire extinguisher.
- e) Personal Protective Equipments shall be provided to the workers during working hours.
- f) Precautionary sign boards and Environmental related messages shall be mounted in and outside of the storage.
- g) Solid waste material shall be disposed off at proper designated site of TMA.
- h) The monitoring team of this Agency shall regularly visit the Project site to check the terms and conditions of the approval and compliance of the Khyber Pakhtunkhwa Environmental Protection Act, 2014. Further, the Management shall facilitate the EPA monitoring team at the time of monitoring.
- i) The proponent shall provide the copy of this approval and IEE Report to the contractor for information and compliance.
- j) Construction / physical works shall be started as per the approved design from the concerned departments.
- k) Entry in to and exit rout from the station shall be metallic and must not hamper the traffic movements in the front of Filling Station.
- l) A proper drainage system shall be provided from the Filling Station & used lube oil in the jet wash shall be properly disposed.
- m) Install and properly fix GENSET in a sound/tremor barring and absorbing cabin having at least 10 feet high duct/stack to reduce noise, vibration and smoke and only operate the GENSET in case of load shading .
- n) Two Washrooms (Male & Female) shall be constructed at the Filling Station. Further, it must be cleaned on daily basis.
- o) Prayer area shall be designated in the Filing Station to facilitate the public.
- p) Service Station is not allowed within the premises of the Filling Station.
- q) Plantation shall be carried out as decided in presentation (10 numbers of successful trees and 50 ornamental plants). Further, two healthy Chinar Plants must be planted between the middle area of IN-OUT position of the project.
- r) Grasses and vegetation around the storage tank is potential source of Ignition. It must be cleared and the area shall be concreted or tiles.
- s) The proponent shall provide Technical & non-technical jobs to the surrounding villagers of the project.
- t) The proponent shall be liable for correctness and validity of the information provided in the Environmental Report.

2/10/20

- 7. The proponent shall be liable for compliance of Regulations 13, 14, 16, 17 and 18 of IEE/EIA Regulations, 2000, regarding approval,

8. This approval is accorded only for the construction phase of the project. The proponent will obtain approval for operation of the project in accordance with the Regulation 13 (2) (b) and 18 of the IEE/EIA Regulations, 2000.
9. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
10. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
11. There shall be no legal case pending in the courts against the project
12. In exercise of the power under Section 13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the IEE Report with above mentioned terms and conditions.

Dated: Peshawar 5 / 5 / 2021.

Tracking/File. No. EPA/IEE/Qatar Petroleum/Dargai/21/2019-20

Director (Malakand)
Environmental Protection Agency (EPA)
Regional Office, Swat