

SCHEDULE-V

Decision on IEE

1. Name, address of proponent: Mr. Faisal Makbool (CEO)
ENERHOME (SMC) Pvt Ltd.
House No 46, Street 59, F-10/3, Islamabad.
2. Description of project: The project site is located at Khasra No 678, Village Khokhar Mera, Tehsil Havelian, District Abbottabad. The project will have a filling capacity of 20MT/Day and Storage capacity of one tank will be 120MT. The construction and operational Phase of the project will require power which will be supplied by Water and Power Development Authority (WAPDA). A transformer will be installed to meet the energy requirement. About 10-12 labors and Technicians will work during construction phase, whereas 20-22 staff will work for the operation of the project.
3. Location of the project: The project is located near Village Khokhar, Tehsil Havelian District Abbottabad (GPS N: 34.08286 E: 73.16252)
4. Date of filling of IEE: 20/12/19
EPA Northern Directorate (Dairy No.4109)
5. After careful review of IEE report, the Environmental Protection Agency, Northern Directorate, Abbottabad, Govt. of Khyber Pakhtunkhwa has decided to accord approval of the Initial Environmental Examination of ENERHOME (SMC-pvt) LTD Village Khokhar Mera, Tehsil Havelian, District Abbottabad of Khyber Pakhtunkhwa in line with the guidelines issued by Pak. EPA and IEE/EIA Regulations, 2000 subject to the following terms & conditions:

[Handwritten signature]



EPA NORTHERN DIRECTORATE, ABBOTTABAD,
Forestry, Environment & Wildlife Department
Govt. of Khyber Pakhtunkhwa

No. EPA/ND/ATD/IEE/LPG 554

Dated: 27/13/19



- a) All the construction and installation in the project area must be carried out according to master plan and instruction provided in NFPA 58 and OGRA rules 2001, (Amended 2014) specially regarding the distance from the houses/building etc.
 - b) The safety and emergency measures should be carried out in the premises of the project area e.g. emergency exits, fire extinguisher as per OGRA rules 2001 (Amended 2014).
 - c) Personal Protective equipments must be provided to all workers to ensure health and health and safety with first aid box for emergency medical coverage.
 - d) Vehicle carrying LPG should be properly labeled with the message indicating existence of LPG etc.
 - e) Environment related message should be mounted in and outside of the storage.
 - f) Mosque should be constructed at the project area.
 - g) The site is not under litigation in any court of law.
 - h) Green corner / plantation should be developed in the premises of the LPG station.
 - i) Sign Boards shall be installed with proper direction.
 - j) Rest room / wash room shall be provided at the Station.
 - k) Gas leakage sensor system shall be installed at appropriate places.
 - l) Safety measures as specified in the Federal Govt. LPG (Production and Distribution) Rules, 2001 amendment in 10th March, 2007 through S.R.O 256 (I)/2007 must be properly implemented at the station.
 - m) Proper drainage & disposal system shall be provided from the LPG Station.
 - n) Entry & exit route from the station shall be metallic and must not hamper traffic movement in front of the LPG station.
 - o) Height of the boundary wall must be up to 10 feet to enclose the compound from outside view and strength the safety.
 - p) Material safety data sheet along with HSE modules shall be provided to the workers.
 - q) Proper training shall be carried out for handling and operating the machinery.
 - r) Impounding concrete flooring shall be constructed around the storage tanks along with underground storage tank for collection of LPG on any on toward incident.
 - s) Alternate access route shall be intact.
 - t) Assembly points shall be identified.
6. Environmental Management Plan must be strictly followed.
7. The proponent shall be liable for correctness and validity of the information supplied by the environmental consultant.



EPA NORTHERN DIRECTORATE, ABBOTTABAD,
Forestry, Environment & Wildlife Department
Govt. of Khyber Pakhtunkhwa




No. EPA/ND/ATD/IEE/LPG 555

Dated: 27/3/19

8. The proponent shall be liable for compliance of section 11, 13, 14, 17 and 18 of IEE/EIA Regulations, 2000, regarding approval, written confirmation of compliance, entry, inspection and monitoring.
9. This approval is accorded only for the "CONSTRUCTION PHASE" of project.
10. The proponent will obtain approval for "OPERATION OF THE PROJECT" in accordance with the section 13 (2) (b) and section 18 of the IEE/EIA Regulations, 2000.
11. The installation site of the crush plant must be 300 meters away from the human settlement.
12. Any change in the approved project shall be communicated to EPA, Northern Directorate, Abbottabad, Khyber Pakhtunkhwa and shall be commenced after obtaining the approval.
13. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
14. There is no legal pending in the courts against the project.
15. In exercise of the power under Section 14 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014 and The Delegation of Powers Vide letter No. EPA/050/01/95 Peshawar, dated the may 19, 2017, the undersigned is pleased to approve the IEE Report for ENERHOME (SMC-pvt) LTD LPG storage and filling plant with the above mentioned terms and conditions.
16. This approval shall be void as null and void if all or any of the conditions mentioned above is/are not complied with.

Dated: Abbottabad 27/3/19

Tracking File No. EPA/ND/ATD/IEE/LPG 555


DIRECTOR (NORTH)
EPA, NORTHERN
DIRECTORATE
HOUSE # CB-136, PMA
KAKUL, ROAD,
ABBOTTABAD