

## Decision on IEE

1. **Name & address of Proponent:**

Mr. Iskander M. Khan,  
Director, Chashma Sugar Mills Limited, King's  
Arcade, 20-A, Markez, F-7, Post Box No. 1529,  
Islamabad.

2. **Description of Project:**

Premier Group has planned to install a 32MW power plant at Chashma Sugar Mill Unit-II. This power plant will use the Sugar Mill Byproduct (Bagasse) as fuel. The main objective of the project is to generate cleaner, economical and reliable energy from indigenous biomass fuel.

3. **Location of Project:**

The Project site is located at District D.I.Khan.

4. **Date of Filing of IEE:**

09/03/2018 Ref. EPA Diary No 373


5. After careful review, the Environmental Protection Agency, Regional Office D.I.Khan has decided to accord approval of the Initial Environmental Examination for "**32MW power plant at Chashma Sugar Mill, Unit-II, District D.I.Khan**" in line with the guidelines issued by Khyber Pakhtunkhwa Environmental Protection Act, 2014 and IEE/EIA Regulations, 2000, subject to the following terms & conditions:-

- a) The proponent shall adopt all precautionary and mitigation measures identified in IEE Report as well as any un-anticipated impacts during the construction and operation phase of the project.
- b) The proponent should ensure the strict compliance of health and safety measures for the protection of workers and visitors.
- c) Plantation should be carried out in the available open spaces of the project area.
- d) Non-technical jobs must be provided to the local community.
- e) The proponent must submit the copy of an agreement, name and address of the hired contractor for solid waste before commencement of the project.
- f) The proponent of the project must install waste water treatment plant and Electrostatic Precipitator (EP) to bring the effluent/emission within the NEQs Permissible Limit.
- g) The proponent of the project must ensure the NEQs level of the drain before discharging waste water into it.
- h) The proponent of the project must submit detailed design of Reverse Osmosis Plant and Electrostatic Precipitator before commencement of the project activities.
- i) The proponent of the project must use only bagass as fuel.
- j) This approval is only accorded for the construction activities of the project and not for any other kind of activities.

- k) No extension would be permitted in the future in the existing project without prior approval of the EPA, Govt. of Khyber Pakhtunkhwa.
- l) The proponent shall provide the copy of this approval and IEE report to the contractor for information and compliance.
  - m) The Self Monitoring Report must be submitted to EPA bi-annually.
  - n) The proponent must provide affidavit regarding the installation of Waste Water Treatment Plant, Electrostatic Precipitator (EP) and Reverse Osmosis Plant in the project.
  - o) Alternate method for control of smoke/dust during Electrostatic Precipitator (EP) tripping hours should also be in place.
  - p) Sign board must be installed at proper locations to avoid accidents.
6. The proponent shall be liable for the correctness and validity of the information supplied by the environmental consultant.
  7. The proponent shall be liable for compliance of Regulations 13, 14, 17 and 18 of IEE/EIA Regulations, 2000, regarding approval, confirmation of compliance, entry, inspections and monitoring.
  8. This approval is accorded only for the installation/ construction phase of the project. The proponent will obtain approval for the operation of the **"32MW power plant at Chashma Sugar Mill, Unit-II"** in accordance with the Regulations 13 (2) (b) and 18 of the IEE/EIA Regulations, 2000.
  9. Any change in the approved project shall be communicated to EPA, Regional Office D.I.Khan and shall be commenced after obtaining the approval.
  10. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
  11. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
  12. There shall be no legal case pending in the courts against the project.
  13. In exercise of the power under Section 13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the IEE Report for the construction phase of the project with above mentioned terms and conditions.

dated: 02/08/2018

Tracking/File.No. **EPA/IEE/32MW/PP-Chashma-2/1287.**



**DIRECTOR,**  
**Environmental Protection Agency,**  
**Regional Office, D.I.Khan.**