

SCHEDULE-V

Decision on Initial Environmental Examination (IEE)

8

6

- Name, address of proponent:** Pakhtunkhwa Energy Development Organization,
(PEDO), Peshawar, Govt. of Khyber Pakhtunkhwa
Phone.091-9217463
2. **Description of project:** The proposed project is going to establish at Village Ghisuch Tehsil & District Manshira. The total Capacity of the project is 15 KW. The gross head is about 45 ft. The existing water of Jabori stream with design discharge 08 cusec will be used for power generation of 15 KW.
3. **Location of the project:** The project is located in Village Ghisuch Tehsil & District Manshira.
4. **Date of filling of IEE:** 08/02/2018
EPA, Northern Directorate (Dairy No. 3007)
5. After careful review, the Environmental Protection Agency, Northern Directorate, Abbottabad, Govt. of Khyber Pakhtunkhwa has decided to accord approval of the Initial Environmental Examination of 15 KW Micro Hydro Power Project at Village Ghisuch Tehsil & District Manshira of Khyber Pakhtunkhwa in line with IEE/EIA Regulations, 2000 subject to the following terms & conditions:
- The proponent will adopt all precautionary and mitigation measures identified in IEE report as well as any unanticipated impacts during the construction and operation phase of project.
 - The proponent must submit monthly compliance report.
 - Employment should be provided to the surrounding villages for unskilled jobs.
 - The proponent should cover the delivery vehicles/construction materials properly with tarpaulin sheet.
 - The proponent must not throw debris/excavated material into river, stream down slope. A proper area should be identified for disposal of debris and provide detail to this office before starting the physical activity/construction at the site.
 - Health Safety equipments (Helmet, gloves, shoes, etc) should be provided to the workers during construction.
 - Plant or distribute among the community and maintain proper record for monitoring i.e. (Kachnar = 100, chir = 100, Pines = 200).
 - Cultural norms/Parda of the area must be maintained and worker must not be allowed for movement in near the houses/women working area.

Amill

- ①
- The existence use of water must not be disturbed.
 - The aquatic biodiversity must not be disturbed in the project area.
 - k) landownership/agreement copy must be provided to the office before starting the construction activities.
 - l) The power generated will only be used for domestic purposes and not for commercial activities.
 - m) Septic tanks and soakage pit must be constructed for the sewage effluent/waste.


Environmental Management Plan must be strictly followed

The proponent shall be liable for correctness and validity of the information supplied by the environmental consultant.

The proponent shall be liable for compliance of section 11, 13, 14, 17 and 18 of IEE/EIA Regulations, 2000, regarding approval, written confirmation of compliance, entry, inspection and monitoring.

- n) This approval is accorded only for the "CONSTRUCTION PHASE" of project.
The proponent will obtain approval for "OPERATION OF THE PROJECT" in accordance with the section 13 (2) (b) and section 18 of the IEE/EIA Regulations, 2000.
10. Any change in the approved project shall be communicated to EPA, Northern Directorate, Abbottabad, Khyber Pakhtunkhwa and shall be commenced after obtaining the approval.
11. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
12. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
13. There is no legal pending in the courts against the project.
14. In exercise of the power under Section 14 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014 and The Delegation of Powers Vide letter No. EPA/050/01/93/ Peshawar, dated the may 19, 2017, the undersigned is pleased to approve the IEE Report for 15 KW Micro Hydro Power Project at Ghisuch Tehsil & District Mansehra with the above mentioned terms and conditions.

Dated: Abbottabad 2/4/18
Tracking/File.No. EPA/ND/IEE/HPP/ Ghisuch/ 47-37


DIRECTOR (NORTH)
EPA, NORTHERN DIRECTORATE
HOUSE # CB-136, PMA, KAKUL ROAD,
ABBOTTABAD