


SCHEDULE-V

Decision on IEE


1. **Name, address of proponent:** Mr. Malik Shahzad Azhar Manger (Admn&HR)
Attock Petroleum Limited 2nd, 7th & 8th Floor, Attock
House, Morgah, Rawalpindi.
Phone No. 051-5127250
Fax No. 051-5127255
2. **Description of project.** M/s Attock Petroleum has intended to establish an APL Bulk Oil Depot at Mouza Korai near Madi/Gandapur Chowk on main bypass road, Tehsil and District D.I.Khan. The total storage capacity is 38,800 metric tons. Total land of 90 Kanals has been acquired for the proposed project. Total cost of the project is Rs one Billion.
3. **Location of project.** The proposed project is located in District D.I.Khan
- | Coordinates | Visited by | Signature |
|-----------------------------|---|---|
| N: 31.85378
E: 070.84125 | Mr. Muhammad Younas Khan,
Assistant Director |  |
4. **Date of filing of IEE** 20-07-2020
(Ref: EPA/Dairy No.453).
5. After a careful review and field visit carried out by Mr. Sana ullah Khan (Director) and Mr. Muhammad Younas Khan (Assistant Director), EPA Southern Directorate D.I.Khan. The Environmental Protection Agency, Govt. of Khyber Pakhtunkhwa has decided to accord conditional construction Environmental approval of the Initial Environmental Examination (IEE) report of , "APL, Bulk Oil Supply Terminal at Dera Ismail Khan" of Khyber Pakhtunkhwa, in line with the guidelines issued under Khyber Pakhtunkhwa Environmental Protection Act, 2014 and IEE/EIA Regulations, 2000 subject to the following terms & conditions:-
- The proponent shall adopt all precautionary and mitigation measures identified in IEE Report as well as any unanticipated impacts during construction phase of the project.
 - All the construction and installation in the project area shall be carried out according to layout plan.
 - The safety and emergency measures shall be carried in the premises of the project area e.g., Emergency Exists, Fire Extinguisher etc.
 - Personal Protective Equipments shall be provided to all workers to ensure health and safety with first aid box for emergency medical coverage.
 - Vehicle carrying oil shall be properly labelled with message indicating existence of oil.
 - Environment and Safety related messages shall be mounted within the premises of the storage area.
 - Mitigation measures must be adopted to control leakages during Improper refueling.

- h) Grasses and vegetation around the storage tank must be cleared and the area shall be concreted or tiled.
- i) The proponent shall provide non-technical jobs to the surrounding localities of the project.
- j) All the emissions/effluents (if any) shall be kept within permissible limits of National Environmental Quality standards (NEQS).
- k) Septic tank must be constructed to treat domestic waste water within the premises of the unit.
- l) The solid waste of the project must be collected and dispose off at the TMA dumping site.
- m) Washroom shall be provided in the project area.
- n) Mosque/prayer place shall be allocated within the project area.
- o) Height of the boundary wall shall be upto 10 feet to enclose the compound from outside view and strengthen the safety.
- p) Plantation of 200 plants of Dakki dates, Lemon, Pine, jaman, Kangi Palm, and Sheshum .etc. must be carried before the operation of the unit.
- q) Parking area must be developed inside the boundary wall of the depot.
- r) EPA monitoring team will regularly visit the project site and suggest further measures for the improvement of environment.
- s) The proponent shall be responsible to facilitate the EPA team during visit/inspection/monitoring.
6. The proponent shall be liable for correctness and validity of the information provided by the Environmental Consultant.
7. The proponent shall be liable for compliance of Regulations 11,13,14,17 and 18 of IEE/EIA Regulations, 2000, regarding approval, confirmation of compliance, entry, inspections and monitoring.
8. This approval is accorded only for the installation/ construction phase of the project. The proponent will obtain approval for operation of the project in accordance with the Regulation 13 (2) (b) and 18 of the IEE/EIA Regulations, 2000.
9. Any change in the approved project shall be communicated to EPA, Khyber Pakhtunkhwa and commenced after obtaining the approval.
10. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
11. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
12. There shall be no legal case pending in the courts against the project.
13. In exercise of the power under Section-13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the IEE Report for construction phase of the project with above mentioned terms and conditions.

Dated: 30/12/2020

Tracking/ File.No. EPA/IEE/Attock-Bulk-oil/DIK/

1085


30/12/2020

DIRECTOR (SOUTH)
EPA, SOUTHERN DIRECTORATE,
D.I.KHAN.