

SCHEDULE-V


Decision on IEE

1. **Name, address of proponent:** Mr. Muhammad Riaz (GM-Works),
Cherat Cement Limited,
P.O Box No 28, Nowshera 24100,
Khyber Pakhtunkhwa.
Ph No 091-5270531-34
2. **Description of project:** Cherat Cement (Pvt) Limited intends to install a Power Plant based on stream driven turbo Generator with a rated capacity of 10 Mega Watt. The Power Plant will utilize the existing Waste Heat of their Cement Plant which is currently wasted as waste gas from steam production. The proposed power plant will be installed at Cherat Cement plant (Line-III) at their existing unit located at District Nowshera.
3. **Location of project:** The project is located at District Nowshera.
4. **Date of filing of IEE:** 03-04-2018 (Ref: EPA/Diary No.686)
5. After a careful review, the Environmental Protection Agency, Govt. of Khyber Pakhtunkhwa has decided to accord approval of the Initial Environmental Examination (IEE) for "10 MW Waste Heat Recovery Power Plant, Cherat Cement Limited Line-III, District Nowshera", in line with the guidelines issued by Khyber Pakhtunkhwa Environmental Protection Act, 2014 and IEE/EIA Regulations, 2000 subject to the following terms & conditions:-
 - a) The proponent will adopt all precautionary and mitigation measures identified in IEE report as well as any un-anticipated impacts during the construction and operation phase of the project.
 - b) All emissions/effluents shall be kept within the permissible limits of National Environmental Quality Standards (NEQS).
 - c) Existing Electrostatic Precipitators (EPs) shall be replaced by Bag House Filter System and shall be maintained properly.
 - d) Tree Plantation shall be carried out as per Plantation Plan provided to EPA.
 - e) Personal Protective Equipments (PPEs) shall be provided to the workers in the factory.

- f) Emergency equipments like Fire Extinguishers, First Aid Box etc shall be displayed at accessible points inside the factory and shall be maintained properly.
 - g) Sign boards shall be installed at appropriate locations inside the factory for guidance and to avoid accidents.
 - h) Non-technical jobs shall be provided to local community and priority should also be given to the technical jobs if available.
6. The proponent shall be liable for correctness and validity of the information supplied by the environmental consultant.
 7. The proponent shall be liable for compliance of Regulations 13, 14, 17 and 18 of IEE/EIA Regulations, 2000, regarding approval, confirmation of compliance, entry, inspections and monitoring.
 8. This approval is accorded only for the installation of the plant which will capture heat for power generation. The proponent shall obtain approval for operation of the project in accordance with the Regulation 13 (2) (b) and 18 of the IEE/EIA Regulations, 2000.
 9. Any change in the approved plant design shall be communicated to EPA, Khyber Pakhtunkhwa and shall be commenced after obtaining the approval.
 10. This approval shall be treated as null and void if any or all of the conditions mentioned above is/are not complied with.
 11. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that shall be required under any law in force.
 12. There shall no legal case pending in the courts against the project.
 13. In exercise of the power under Section 13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the IEE Report with above mentioned terms and conditions.

Dated: Peshawar ___/___/2018

Tracking/File. No. EPA/IEE/Cement/Cherat-Unit-III/10MW-WHR/18/


**DIRECTOR GENERAL,
EPA, Khyber Pakhtunkhwa.
3rd Floor, SDU Building,
Khyber Road Peshawar.**