

Duplicate


SCHEDULE-VI

Decision on EIA

1. **Name, address of proponent:** Abdul Latif Khan,
Chief Engineer (Development),
Project Management Unit PESCO
WAPDA House Shami Road
Peshawar
Ph. No. 091-9210987.
2. **Description of project.** The project is planned to construct 132 KV Grid Station at Gomal University D.I.Khan and 2,110 meter double circuit transmission line. It is located near Gomal University D.I.Khan and will be constructed on 64 Kanals land provided by Gomal University to PESCO. It will be connected to the existing Taunsa-D.I.Khan 132 KV transmission line , by constructing 132 KV double circuit transmission line. It involve in the construction of total of 09 towers
3. **Location of project.** The project is located in D.I.Khan.
4. **Date of filing of EIA.** 29-01-2011
Ref. (EPA Diary No. 198)
5. After careful review, the Environmental Protection Agency, Govt. of Khybar Pakhtunkhwa has decided to accord approval of the Environmental Impact Assessment of 132 KV Grid Station and 2,110 meter double circuit transmission line under Power Distribution Enhancement MFF Project in District D.I.Khan of Khybar Pakhtunkhwa in line with the guidelines issued by Pak. EPA and IEE/EIA Regulations, 2000 subject to the following terms & conditions:-
 - a) The proponent will adopt all precautionary and mitigatory measures identified in EIA report as well as any unanticipated impacts during the construction and operation phase of project.
 - b) The proponent must submit annually compliance report.
 - c) Submission certification for restoration of site after completion of the activity.
 - d) The proponent should provide copy of land agreement with property owner of farm land where 04 towers will be installed on their private land.
 - e) PESCO should bound the contractor in bidding documents to provide power transformer having PCB free oil.
 - f) Oil filled transformer should be directly supplied from source to the Grid Station.
 - g) Water should be regularly sprinkled on the road within the project site to control dust.

- h) A copy of the agreement made with the contractor for the mitigation measures/control of environmental/ social pollution during construction process should be provided.
- i) Compensation for crops & trees should be paid to the owner at the market rate as per Govt rules.
- j) Employment should be provided to local people particularly for unskilled jobs. Employment record for all position should be provided to EPA, Khybar Pakhtunkhwa.
- k) Health and Safety measures should be provided to the staff both in construction and operational phase.
6. The proponent shall be liable for correctness and validity of the information supplied by the environmental consultant.
7. The proponent shall be liable for compliance of Sections 13, 14, 17 and 18 of IEE/EIA Regulations, 2000, regarding approval, confirmation of compliance, entry, inspections and monitoring.
8. This approval is accorded only for the construction phase of the project. The proponent will obtain approval for operation of the project in accordance with the Section 13 (2) (b) and Section 18 of the IEE/EIA Regulations, 2000.
9. Any change in the approved project shall be communicated to EPA, NWFP and shall be commenced after obtaining the approval.
10. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
11. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
12. There is no legal case pending in the courts against the project.
13. In exercise of the power under Section 12 of the Pakistan Environmental Protection Act, 1997, the undersigned is pleased to approve the EIA Report for 132 KV D.I.Khan Industrial (Gomal University) Grid Station and 2,110 meter long double circuit transmission line under Power Transmission Enhancement Project with above mentioned terms and conditions.

Dated: Peshawar 12-10-2011
Tracking/File.No. EPA/EIA/G-A/119


DIRECTOR GENERAL
EPA, Khybar Pakhtunkhwa.
3rd Floor, S.D.U. Building,
Khyber Road Peshawar
Cantt. 15/10