

SCHEDULE-V
Decision on IEE

1. **Name & address of Proponent:** Mr. Muhammad Ishaq Khan, CEO, Muslim Bagh Gas Pvt. Ltd. at Main GT Road, Serai Naurang, District Lakki Marwat.

2. **Description of Project:**

Muslim Bagh Gas Private Ltd. has intended to construct LPG Storage and Filling Plant at Muslim Bagh, Tehsil Serai Naurang District Lakki Marwat. Total 22 Kanal land has been acquired for the Project. The main aim of the project is to provide a safe, economic friendly LPG Bottles to the LPG Suppliers and direct consumers. The total estimated cost of the project is 15million. The estimated life of the First Phase of the Project is 50Years.

3. **Location of Project:**

The Project site is located at District Lakki Marwat.

4. **Date of Filing of IEE:**

20.07.2018 Ref. EPA Diary No 833


5. After careful review, the Environmental Protection Agency, Regional Office D.I.Khan has decided to accord approval of the Initial Environmental Examination for "LPG Storage and Filling Plant of Muslim Bagh Gas Pvt Limited at Muslim Bagh, Tehsil Serai Naurang District Lakki Marwat" in line with the guidelines issued by Khyber Pakhtunkhwa Environmental Protection Act, 2014 and IEE/EIA Regulations, 2000, subject to the following terms & conditions:-

- a) The proponent will adopt all precautionary and mitigation measures identified in IEE Report as well as any un-anticipated impacts during the construction and operation phase of the project.
- b) All the construction and installation must be carried out according to the master plan and instruction provided by OGRA.
- c) All the safety and emergency measures should be carried out within the premises of the project area as per OGRA Rules.
- d) Vehicle carrying LPG should be properly labeled with the message indicating the existence of LPG, etc.
- e) Environmental related messages should be mounted in and outside of the storage.
- f) Personal protective equipments must be provided to all the workers to ensure health and safety.
- g) Height of the boundary wall must be increased from seven (07) feet to ten (10) feet to enclose the compound from outside view and strengthen the safety.
- h) Grasses and vegetation around the storage tanks is potential source of ignition when dried. Therefore, it must be cleared and the area shall be concreted or tiled.
- i) The Land ownership documents/acquisition/lease agreement shall be provided to this Agency.
- j) Plantation should be carried out around the project area.

- Non-technical jobs must be provided to the local community.
- l) This approval is only issued for the construction activities of the project and not for any other kind of activities.
 - m) No extension would be permitted in future in the existing project without prior approval of this Agency.
 - n) NOC from Explosive Department must be provided to this Agency before initiation of Physical activities.
 - o) Renewal of approval after re-assessing the site on annual basis as per instruction of OGRA letter No. OGRA-23 (13)/2014-Enf dated 15-09-2014, shall be submitted to EPA.
6. The proponent shall be liable for the correctness and validity of the Information supplied by the environmental consultant.
 7. The proponent shall be liable for compliance of Regulations 13, 14, 17 and 18 of IEE/EIA Regulations, 2000, regarding approval, confirmation of compliance, entry, inspections and monitoring.
 8. This approval is accorded only for the installation/ construction phase of the project. The proponent will obtain approval for the operation of the LPG Storage and Filling Plant, in accordance with the Regulations 13 (2) (b) and 18 of the IEE/EIA Regulations, 2000.
 9. Any change in the approved project shall be communicated to EPA, Regional Office D.I.Khan and shall be commenced after obtaining the approval.
 10. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
 11. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
 12. There shall be no legal case pending in the courts against the project.
 13. In exercise of the power under Section 13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the IEE Report for the construction phase of the project with above mentioned terms and conditions.

Dated: 25/10/2018

Tracking/File No. EPA/IEE/ MB-LPG Storage and Filling Plant/1414-16


DIRECTOR,

Environmental Protection Agency,
Regional Office, D.I.Khan.