

4

SCHEDULE-V

Decision on IEE

Name & address of Proponent:

Mian Shahzad Latif,
M/S Shahzad LPG Private Ltd,
House No. 329, Street 102,
Sector I-8/4, Islamabad.
Ph No. 0300-5555765

Description of Project:

M/S Shahzad LPG (Pvt) Limited is located at Shinku Banda, Union Council Kutch, Tehsil & District Hangu. The proposed project is establishment of LPG storage and filling plant with a filling capacity of 10-20M/Day and one tank with storage capacity of 50 MT. total area of the project is 20 Kanal.

3. Location of Project:

The project site is located at District Hangu.

4. Date of Filing of IEE:

11-12-2018 (Ref: EPA Diary No.682)

5. After careful review, the Environmental Protection Agency , Govt. of Khyber Pakhtunkhwa has decided to accord approval of the Initial Environmental Examination for "Shahzad LPG (Pvt) Limited District Hangu, Khyber Pakhtunkhwa" in line with the guidelines issued by Khyber Pakhtunkhwa Environmental Protection Act, 2014 and IEE/EIA Regulations, 2000, subject to the following terms & conditions:-

- a) The proponent shall adopt all precautionary and mitigation measures identified in IEE Report as well as any un-anticipated impacts during the construction and operation phase of project.
- b) All the construction and installation in the project area must be carried out according to Master Plan and instructions provided in NFPA 58 and OGRA Rules 2001, (Amended 2014) specially regarding the distance from the houses/buildings etc.
- c) The safety and emergency measures shall be carried out in the premises of the project area e.g. emergency exits, fire extinguisher as per OGRA Rules 2001 (amended 2014).

d) Renewal of approval after re-assessing the site on annual basis as per instruction of OGRA letter No. OGRA-23(13)/2014-Enf dated 15-09-2014.

e) The proponent should take sufficient security arrangements in view of sensitivity of the area.

f) Personal protective equipments shall be provided to all workers to ensure health and safety with first aid box for emergency medical coverage.

g) Vehicle carrying LPG shall be properly labeled with the message indicating existence of LPG etc.

h) Environmental related messages shall be mounted in and outside of the storage.

i) Washroom shall be provided at the storage area.

j) Plantation along the boundary wall and in open space shall be carried out.

k) Grasses and vegetation around the storage tank is potential source of ignition when dried. Therefore, it shall be cleared and the area shall be concreted or tiled. Moreover, impounding concrete flooring along with underground storage Tank shall be carried out around storage Tanks.

l) Soap testing of all joints and pipes shall be carried out regularly to check leakage and take appropriate mitigation measures.

m) Ring road route shall be adopted to approach the project site as per instructions of the office of the Superintendent of the Traffic Police, Peshawar vide letter No 1926/GC dated 31-05-2016.

6. The proponent shall be liable for correctness and validity of the information supplied by the environmental consultant.

7. The proponent shall be liable for compliance of Regulations 13, 14, 17 and 18 of IEE/EIA Regulations, 2000, regarding approval, confirmation of compliance, entry, inspections and monitoring.

8. This approval is accorded only for the installation/ construction phase of the project. The proponent shall obtain approval for operation of the hydro power project in accordance with the Regulation 13 (2) (b) and 18 of the IEE/EIA Regulations, 2000.


9. Any change in the approved project shall be communicated to EPA, Khyber Pakhtunkhwa and shall be commenced after obtaining the approval.

This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.

- 11. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
- 12. There shall be no pending legal case in the courts against the project.
- 13. In exercise of the power under Section 13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the IEE Report for construction phase of the project with above mentioned terms and conditions.

Dated: Peshawar 11/2/2019

Tracking/File.No. No. EPA/IEE/OIL&GAS/Shahzad-LPG-Hangu/19/391


**DIRECTOR GENERAL,
EPA, Khyber Pakhtunkhwa,
3rd Floor, SDU Building,
Khyber Road, Peshawar Cantt.**