


SCHEDULE-V

Decision on IEE

1. Name, address of proponent: Mr. Waheed Ullah Khan  
Chief Executive Officer  
M/S Waheed Gas private Limited.  
GT Road, Firdos Al-Muzamil Mention Near  
Nasho Baba Masjid, Peshawar  
Cell # +92-300-5779611
2. Description of project: M/S Waheed Gas (Pvt) Ltd. has intended to install a Liquefied Petroleum Gas (LPG) storage and filling Facility at Meshto Banda. District Hangu. The storage capacity of the plant is 60 metric tons and filling capacity is 20 MT /day. Total estimated cost of the project is Rs. 50 million. Total area of the project is 16 kanal.


3. Location of project: The project is located at District Hangu.

Coordinates	visited by	Signature
N 3329.503	Mr. Muhammad Younas Khan.	
E 07102.757	Assistant Director	

4. Date of filing of IEE: 27-07-2020  
(Ref: EPA/Diary No. 471)

5. After a careful review and field visit report carried out by Mr. Muhammad Younas Khan, Assistant Director, EPA Southern Directorate D.I.Khan. The Environmental Protection Agency, Govt. of Khyber Pakhtunkhwa has decided to accord conditional construction Environmental approval of the Initial Environmental Examination (IEE) report of Liquefied Petroleum Gas (LPG) storage and filling Facility of M/S Waheed Gas (Pvt) Ltd District Hangu Khyber Pakhtunkhwa. in line with the guidelines issued under Khyber Pakhtunkhwa Environmental Protection Act, 2014 and IEE/EIA Regulations, 2000 subject to the following terms & conditions:-

- a) The proponent shall adopt all precautionary and mitigation measures identified in IEE Report as well as any unanticipated impacts during construction phase of the project.

verified  
  
6/7/21  
Assistant Director  
Environmental Protection Agency  
Southern Directorate D.I. Khan

- b) All the construction and installation in the project area shall be carried out according to master plan and instructions provided in NFPA 58 and OGRA Rules 2001 (Amended 2014) specially regarding the distance from houses/buildings etc.
- c) The safety and emergency measures shall be carried in the premises of the project area e.g., Emergency Exits, Fire Extinguisher as per OGRA Rules 2001(amended 2014).
- d) Personal Protective Equipments shall be provided to all workers to ensure health and safety with first aid box for emergency medical coverage.
- e) Vehicle carrying LPG shall be properly labelled with message indicating existence of LPG etc.

- f) Environment and Safety related messages shall be mounted in and outside of the storage.
- g) Washroom shall be provided in the project area.
- h) Mosque/prayer place shall be allocated within the project area.
- i) Height of the boundary wall shall be upto 10 feet to enclose the compound from outside view and strengthen the safety.
- j) Plantation of 75 plants of Dakkidates, Lemon, Pine, jamun, Kangi palm, and Sheshum etc. before the operation of the unit.
- k) Grasses and vegetation around the storage tank is potential source of Ignition. It shall be cleared and the area shall be concreted or tiled.
- l) Soap testing of all joints and pipes shall be carried out regularly to check leakage and take appropriate mitigation measures.
- m) The proponent shall provide non-technical jobs to the surrounding villages of the project.
- n) All the emissions/effluents (if any) shall be kept within permissible limits of National Environmental Quality standards (NEQS).
- o) Septic tank must be constructed to treat domestic waste water within the premises of the unit.
- p) EPA monitoring team will regularly visit the project site and suggest further measures for the improvement of environment.
- q) The proponent shall be responsible to facilitate the EPA team during visit/inspection/monitoring.

*(Handwritten signature)*

verified  
 #1115  
 6/7/21  
 Assistant Director  
 Environmental Protection Agency  
 Southern Directorate D. J. Khar

- 6. The proponent shall be liable for correctness and validity of the information provided by the Environmental Consultant.
- 7. The proponent shall be liable for compliance of Regulations 11,13,14,17 and 18 of IEE/EIA Regulations, 2000, regarding approval, confirmation of compliance, entry, inspections and monitoring.

- 8. This approval is accorded only for the installation/ construction phase of the project. ✓  
The proponent will obtain approval for operation of the project in accordance with the Regulation 13 (2) (b) and 18 of the IEE/EIA Regulations, 2000.
- 9. Any change in the approved project shall be communicated to EPA, Khyber Pakhtunkhwa and shall be commenced after obtaining the approval.
- 10. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
- 11. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
- 12. There shall be no legal case pending in the courts against the project.
- 13. In exercise of the power under Section-13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the IEE Report for construction phase of the project with above mentioned terms and conditions.

Dated: 07/10/2020

Tracking/File.No. EPA/IEE/Waheed-LPG/Hangu/ 101

verified  
 #115  
 6/7/21  
 Assistant Director  
 Environmental Protection Agency  
 Southern Directorate D.I. Khan

*[Signature]*  
 6/7/2020

DIRECTOR (SOUTH)  
 EPA, SOUTHERN DIRECTORATE,  
 D.I.KHAN.