



EPA NORTHERN DIRECTORATE, ABBOTTABAD
Forestry, Environment & Wildlife Department
Govt. of Khyber Pakhtunkhwa



No.EPA/ND/ATD/2020/ 1883

Dated: 20-1-2021

To

Mr. Syed Mohsin Ali Shah S/o Syed Sarwar Shah,
Sadaat Filling Station, Lora Chowk,
District Haripur.

Subject: **REQUEST FOR ISSUING OF NOC FOR SADAAT FILLING STATION, LORA CHOWK, DISTRICT HARIPUR.**

Kindly, refer to your application no nil dated nil on the above noted subject and to state that the competent authority is pleased to accord environmental approval for installation of Petrol Pump namely "SADAAT FILLING STATION" subject to the following conditions:

1. Construction/physical works shall be started as per approved design from concerned Chief Municipal Officer.
2. The Safety measures as specified in Petroleum Rules as well as proposed by Director General (Petroleum) must be properly implemented.
3. Entry in to and exit rout from the station shall be metallic and must not hamper the traffic movement in front of the station.
4. A proper drainage system shall be provided from the Filling Station & used lube oil in the jet wash shall be properly disposed off.
5. Two rest / wash rooms (Male & Female) should be provided at the Station.
6. Mosque should be constructed at the Station.
7. Environmental messages must be mounted at the site.
8. Service Station is not allowed within the premises of Filling Station.
9. Front of the petrol pump shall be 40 ft space for in, 40 ft space for out and middle space 50 ft in which 3 pine and 3 chinar plants shall be planted.
10. On one side having space of 4/30 ft 2 chinar and 02 deodar plants shall be planted.
11. Construct the 4FR (Fire and Shock Resistant) wall minimum of 10 feet height towards the school and underground tanks installed away from the school.

Environmental Protection Agency reserves the right to check and to ensure the implementation of pollution control measures at the station any time.


DIRECTOR (NORTH)

CC:

- Director General, EPA, Peshawar, Govt. of Khyber Pakhtunkhwa
- Deputy Commissioner, District Haripur

House No.CB-59, PMA Kakul Road, Abbottabad. Phone No. 0992-9310472

Received.


21/1/2021