

SCHEDULE-V

Decision on IEE

1. **Name, address of proponent:** Muhammad Iqbal Butt,
Chief Executive Officer,
Exceed Petroleum Pvt. Ltd.
Office No. 1204, 12th Floor Green Trust
Tower, Jinnah Avenue Blue Area, Islamabad.

2. **Description of project.** Exceed Petroleum (Pvt.) Ltd. plans to construct an Oil storage terminal at land measuring 59-kanal (59K-0m-0sft), out of land bearing Khata Khatooni No.41/92 min, 92 min, Khasra No.44, 45/2 and 45/3, Qita No. 2, situated at Gull Dhairy, falling in the revenue estate of Mouza "Dhokla" Tehsil and District Nowshera (KPK). To facilitate its operations and provide storage for the products, the company intends to install 01 Vertical Above ground Tank of approximate capacity 3000 metric Ton for D.P Premium Motor Gasoline (PMG) storage, and 01 Vertical above ground Tank of approximate capacity 3000 metric Ton for High Speed Diesel (HSD) storage. The total capacity of the terminal is 6000 metric Tons.

3. **Location of project.** The proposed project is located in District Nowshera.
GPS Coordinates: N33°56'30.3" - E72°5'13.8

4. **Date of filing of IEE.** 30/07/2019 (Ref EPA/Diary No. 382)

5. After a careful review, the Environmental Protection Agency, Govt. of Khyber Pakhtunkhwa has decided to accord conditional approval of the Initial Environmental Examination (IEE) Report of "**Exceed Petroleum (Pvt.) Ltd. at District Nowshera**" in line with the guidelines issued by Khyber Pakhtunkhwa Environmental Protection Act, 2014 and IEE/EIA Regulations, 2000 subject to the following terms & conditions:-
 - a) The proponent shall adopt all precautionary and mitigation measures recommended in the IEE Report/comments/replies of the proponent

submitted to this Agency and any un-anticipated impacts arising during the construction and operation phase of the project.


- b) The proponent shall ensure the compliance and implementation of the National Environmental Quality Standards (NEQS) for all effluents and emission during construction and operational phase of the project.
- c) The safety and emergency measures shall be carried out in the premises of the project area e.g. emergency exits, Fire Extinguisher, Water Tanks, Sprinkling System as per OGRA Rules. Moreover, arrangement will be made with 1122, Fire Fighter Department for emergency services.
- d) The proponent shall ensure sufficient security measures due to the sensitivity of the project i.e. installation of CCTV Cameras, maximum height of boundary wall etc.)
- e) Personal protective equipments shall be provided to the workers in order to ensure health and safety. Moreover, first aid box for emergency medical coverage shall be available on project site.
- f) Proper diking shall be carried out around the storage tanks.
- g) Vehicle carrying the Products shall be properly labeled with the message indicating existence of flammable Products, etc.
- h) The access road shall be extended up to the maximum width to avoid traffic congestion. Moreover, Vehicle movement shall be avoided during school timings
- i) The vehicles shall be parked in the designated parking area inside the oil depot.
- j) Environment related messages shall be mounted in and outside of the storage.
- k) Solid waste/Debris/Excavated material shall be disposed off at designated site with the prior permission of respective authority (i.e. TMA, etc.)
- l) Washroom shall be provided at the storage area.
- m) Plantation of 200 successful plants shall be carried out along the boundary wall and in open space.
- n) Grasses and vegetation around the storage tank is potential source of ignition when dried. Therefore, the same shall be cleared and the area be concreted or tiled.

- o) The monitoring team of this Agency shall regularly visit the Project site to check the terms and conditions of the approval and compliance of the Khyber Pakhtunkhwa Environmental Protection Act, 2014.
 - p) Non-technical jobs shall be provided to the local people of the area.
 - q) The proponent shall provide the copy of this approval and IEE Report to the contractor for information and compliance.
 - r) The storage tank shall be installed at the minimum distance of 100m from the residential area.
 - s) Oil & Water separator shall be installed for waste water and reuse of treated water shall be ensured.
 - t) An affidavit shall be provided reflecting that the storage area of the project shall not be used for purpose other than storage of Petroleum.
 - u) A buffer zone shall be maintained between the oil storage tanks and office, human settlement, etc.
 - v) A committee comprising representative of locals shall be constituted to deal issued arising from project activity.
 - w) The proponent shall submit environmental monitor plan after every 06 months.
 - x) Measures shall be taken to avoid contamination of soil, air, water, etc. from oil leakage. Transport site shall have retention facilities capable of accommodating escaped liquid to avoid explosive, fire, any other hazard.
 - y) To avoid any hazard, the project shall be designed, constructed and operated as per OGRA Rules.
 - z) Hazardous substance Rules, 2005, shall be observed in Handling, Storage and Transport of Oil.
- . The proponent shall be liable for correctness and validity of the information provided in the environmental report.
 - . The proponent shall be liable for compliance of Regulations 13, 14, 17 and 18 of IEE/EIA Regulations, 2000, regarding approval, confirmation of compliance, entry, inspections and monitoring.
 - . This approval is accorded only for the construction phase of the project. The proponent will obtain approval for operation of the project in accordance with the Regulation 13 (2) (b) and 18 of the IEE/EIA Regulations, 2000.

9. Any change in the approved project shall be communicated to EPA, Khyber Pakhtunkhwa and shall be commenced after obtaining the approval.
10. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
11. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
12. There shall be no legal case pending in the courts against the project
13. In exercise of the power under Section 13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the EIA Report with above mentioned terms and conditions.

Dated: **Peshawar** 09 / 03 / 2020

Tracking/File.No. EPA/IEE/Oil&Gas/Petroleum/Exceed/Now/20/56-57


DIRECTOR GENERAL
EPA, Khyber Pakhtunkhwa.
3rd Floor, SDU Building,
Khyber Road Peshawar.