



Environmental Protection Agency
Forestry, Environment & Wildlife Department
Govt. of Khyber Pakhtunkhwa



No. EPA/IEE/Oil&Gas/Naseem-Khan/Mardan/19/506

Date: 17/5/2019

To

Mr. Naseem Khan,
CEO of Naseem Khan Petroleum Pvt. Ltd,
Head Office, Plot No. 155, Service Road.
North, I-9/3- Industrial Area Islamabad,
Pakistan.
Phone No. 0310-5045313

Subject: **MITIGATION MEASURES FOR ENVIRONMENTAL IMPROVEMENT**

Reference to your letter No. EPA-NOC/LPG-2019 Dated 18/04/2019 on the subject cited above and Environmental Protection Tribunal (EPT) decision made on 25/02/2019 and to state that this office grant approval to LPG Storage & Bottling Plant at Planning Stage, while in the instant case, the unit has already been constructed therefore, the following mitigation measures shall be adopted for environmental improvement during operation.

1. The safety and emergency measures shall be carried out in the premises of the project area e.g. emergency exits, fire extinguisher as per OGRA Rules 2001 (amended 2014).
2. Personal protective equipments shall be provided to all workers to ensure health and safety with first aid box for emergency medical coverage.
3. Environment related messages shall be mounted in and outside of the storage.
4. Vehicle carrying LPG shall be properly labeled with the message indicating existence of LPG etc.
5. Existing Right of Way (RoW) and traffic shall not be disturbed. Moreover, separate designated parking area shall be allotted for vehicles.
6. Washroom shall be provided at the storage area.
7. Plantation along the boundary wall and in open space shall be carried out.
8. Grasses and vegetation around the storage tank is potential source of ignition when dried. Therefore, it shall be cleared and the area shall be concreted or tiled. Moreover, impounding concrete flooring along with underground storage Tank shall be carried out around storage Tanks.

D:\EIA Section 2011\Sectors\Oil & Gas\Naseem Khan LPG district Mardan

3rd Floor, Old Courts Building, Khyber Road, Peshawar Cantt
Telephone: 92 (91) 9210263, Fax: 92 (91) 9210280

Page 1 of 2

9. Soap testing of all joints and pipes shall be carried out regularly to check leakage and take appropriate mitigation measures.
10. Renewal of approval after re-assessing the site on annual basis as per instruction of OGRA letter No. OGRA-23(13)/2014-Enf dated 15-09-2014.
11. The proponent should take sufficient security arrangements in view of sensitivity of the area.

Furthermore, the monitoring team of this Agency will carry out routine monitoring to check the compliance of above mentioned mitigation measures within a month time. In case of non-compliance, action will be initiated under the Khyber Pakhtunkhwa Environmental Protection Act, 2014.



DIRECTOR GENERAL,