



15705-3



**ENVIRONMENTAL PROTECTION
AGENCY REGIONAL OFFICE
SWAT**
FORESTRY, ENVIRONMENT & WILDLIFE
DEPARTMENT GOVT. OF KHYBER
PAKHTUNKHWA



NO. EPA/DS/NOC/PP/ 2024 Date. 20/11/2019

To

Mr. Shahid Zamin s/o Gul Muhammad,
Owner of Gul Filling Station,
Dhab Rabat, Dir - Timergara Road, Tehsil Balambat , District Dir Lower.

Subject:

**INSTALLATION OF MS/HSD RETAIL OUTLET AT KHEWAT NO/ KHATONI
NO/ KHASRA NO, SITUATED AT DIR TIMERGARA CHITRAL ROAD AT
RABAT DHAB, TEHSIL BALAMBAT, DISTRICT DIR LOWER.**

Reference to your application No. Nill Dated: 14/11/2019 on the subject noted above and to state that convey your Environmental Clearance for the installation of **HASCOL PETROLIUM Limited.** (Gul Filling Station, at Dhab Rabat, Dir - Timergara Road, Tehsil Balambat , District Dir Lower), subject to the following conditions:

1. Construction / physical works shall be started as per the approved design from the concerned departments.
2. The Safety measures as specified in Petroleum Rules as well as proposed by Director General (Petroleum) must be properly implemented.
3. Entry in to and exit rout from the station shall be metallic and must not hamper the traffic movement in the front of Filling Station.
4. A proper drainage system shall be provided from the Filling Station & used lube oil in the jet wash shall be properly disposed.
5. Two rest / wash rooms (Male & Female) tanks should be provided at the Filling Station.
6. Septic tanks must be constructed for toilet waste / effluents.
7. Prayer area shall be designated in the Filing Station to facilitate the public.
8. Precautionary sign boards and Environmental messages must be mounted at appropriate sites.
9. Service Station is not allowed within the premises of Filling Station.
10. Trees of ornamental nature should be planted in and around the Filling Station and shall take care of the same.

Environmental Protection Agency reserves the right to check and to ensure the implementation of pollution control measures at the project area. Moreover, in case of non compliance with any of the above mentioned conditions, this approval will be considered null and void.

CC:

- PA to Director General, EPA, Govt. of Khyber PakhtunKhwa, Peshawar.

Director (Malakand)

House No.2, Chinar Colony, Near Grassy Ground, Amankot, Saidu Sharif, Swat
Phone No. 0946-9240098