



DIRECTORATE OF MALAKAND
ENVIRONMENTAL PROTECTION AGENCY
REGIONAL OFFICE SWAT

FORESTRY, ENVIRONMENT & WILDLIFE
DEPARTMENT GOVT. OF KHYBER PAKHTUNKHWA

No. EPA/DS/551 Date: 26/02/2020

To

Mr. Waseel Khan S/O Latif Khan,
Owner of Haji Peer Latif Khan Filling Station (Proposed),
Resident of Village Qaldara, Tehsil Dargai, District Malakand.

Subject:

ISSUANCE OF "NO OBJECTION CERTIFICATE" FOR INSTALLATION OF "GOPL" PETROL PUMP LOCATED AT AS PER CONFIRMATION STAMP FROM NAIB TEHSILDAR, DARGAI, REF NO. 793, DATED 02/10/2019, DISTRICT MALAKAND.

Reference to a letter No. 2349-55/Coord Dated: 27/01/2020 received from the Office of Additional Deputy Commissioner Malakand on the subject cited above and to convey your Environmental Clearance for the installation of **Gas & Oil Pakistan Ltd**, named as **Haji Peer Latif Khan Filling Station, only Petrol pump**, located on plot situated at Dargai on main NHA road, (N-45), at Tehsil Dargai, District Malakand subject to the following conditions:

1. Construction / physical works shall be started as per the approved design from the concerned departments.
2. The Safety measures as specified in Petroleum Rules as well as proposed by Director General (Petroleum) must be properly implemented.
3. Entry in to and exit rout from the station shall be metallic and must not hamper the traffic movements in the front of Filling Station.
4. A proper drainage system shall be provided from the Filling Station & used lube oil in the jet wash shall be properly disposed.
5. Two rest / wash rooms (Male & Female) should be provided at the Filling Station.
6. Septic tanks must be constructed for toilet waste/ effluents.
7. Prayer area shall be designated in the Filing Station to facilitate the public.
8. Precautionary sign boards and Environmental messages must be mounted at appropriate sites.
9. Service Station is not allowed within the premises of the Filling Station.
10. Trees of ornamental nature should be planted in and around the Filling Station and shall take care of the same.

Environmental Protection Agency reserves the right to check and to ensure the implementation of pollution control measures at the project area. Moreover, in case of non compliance with any of the above mentioned conditions, this approval will be considered null and void.

Waseel Khan 26/2/2020

Waseel Khan

[Signature]
Director (Malakand)

cc:

03439097391

o/c

- Additional Deputy Commissioner, District Malakand with reference to letter No. 2349-55/Coord Dated: 27/01/2020.
- PA to Director General, EPA, Govt. of Khyber PakhtunKhwa, Peshawar.

Mohalla Faiz Abad, Near Chinar Masjid (Jamia Masjid Sadiqia), Tehsil Babozai, District Swat.