



**DIRECTORATE OF MALAKAND
ENVIRONMENTAL PROTECTION AGENCY
REGIONAL OFFICE SWAT**
FORESTRY, ENVIRONMENT & WILDLIFE DEPARTMENT
GOVT. OF KHYBER PAKHTUNKHWA



No. EPA/Onyx lpg/Talash/Dir Lower/2443 Date: 24/11/21

To

Mr. waqar Umar,
Chief Executive Officer,
M/S Onyx Storage & Bottling Plant (Pvt) Ltd,
Tehsil Temergara, District Dir Lower,
Contact No. 0334-9089081

**Sub: CONSTRUCTION PHASE APPROVAL FOR REMAINING CIVIL WORK
TO M/S ONYX LPG STORAGE AND BOTTLING PLANT
LOCATED AT MAIN DIR ROAD, DHERI STOP, SHAMI KHAN,
ZIARAT TALASH, TEHSIL TIMERGARA, DISTRICT DIR LOWER**

Kindly refer to the Deputy Commissioner Dir Lower office letter No. 2622-25/16/AG, dated 19-2-2020 and followed by your application No. Nil, dated Nil received to this office on 24-12-2020, 01-01-2021 and 08-08-2021 respectively, visits were conducted by this office on, 25-07-2020 and 03-02-2020. The case was referred to the Environmental Protection Tribunal for violation of section 13 of Khyber Pakhtunkhwa Environmental Protection Act, 2014. Now in the light of worthy Environmental Protection Tribunal judgment dated, 30-07-2021, this office allow you to continue the remaining civil work on the Onyx LPG storage and bottling plant located at main Dir Road, Dheri stop, Shamsi Khan, Ziarat Talash, Tehsil Temergara, District Dir Lower bearing GPS coordinates N: 34.748102, E: 071.844045 subject to the following terms and conditions.

- The proponent shall adopt all precautionary and mitigation measures identified in EMP Report as well as any unanticipated impacts during construction and operation phase of the project.
- All the construction and installation in the project area shall be carried out according to master plan and instructions provided in NFPA 58 and OGRA Rules 2001 (Amended 2014) specially, regarding the distance from houses/buildings etc.
- The safety and emergency measures shall be carried in the premises of the project area e.g., Emergency Exits, Fire Extinguisher as per OGRA Rules 2001(amended 2014).
- Personal Protective Equipments shall be provided to all workers to ensure health and safety with first aid box for emergency medical coverage.
- Vehicle carrying LPG shall be properly labelled with message indicating existence of LPG etc.
- Environment and Safety related messages shall be mounted in and outside of the unit.
- Washroom shall be provided in the project area.
- Mosque/prayer place shall be allocated within the project area.
- Height of the boundary wall shall be upto 10 feet to enclose the compound from outside view and strengthen the safety.

Reviewed by
Waqar Umar
24/11/21

- j) Total 30 plants/trees of local species shall be planted along the boundary wall and available spaces within the project area.
- k) Grasses and vegetation around the storage tank is potential source of Ignition. It shall be cleared and the area shall be concreted or tiled.
- l) Soap testing of all joints and pipes shall be carried out regularly to check leakage and take appropriate mitigation measures.
- m) The proponent shall provide non-technical jobs to the surrounding villages of the project.
- n) All the emissions/effluents (if any) shall be kept within permissible limits of National Environmental Quality standards (NEQS).
- o) Septic tank must be constructed to treat domestic waste water within the premises of the unit.
- p) Proper Parking facility must be provided within the project area for loading and unloading vehicles.
- q) A sign board must be displayed near the gate side/ entrance route for general information to the public regarding name of the project, name of the Proponent, Contact number of the proponent, name of in-charge of the unit and his contact number etc.
- r) Solid waste of the project must be collected and disposed of at the properly designated dumping site.
- s) As per the worthy Environmental Protection Tribunal Judgment/ Order Sheet, The two residential houses shall be vacated as the construction work started at the project site.
- t) EPA monitoring team will regularly visit the project site and suggest further measures for the improvement of environment.
- u) The proponent shall be responsible to facilitate the EPA team during visit/inspection/monitoring.
- v) The proponent shall be liable for correctness and validity of the information provided by the Environmental Consultant.
- w) This approval is accorded only for the installation/ construction phase of the project. The proponent will obtain approval for operation phase as well as renewal of the operation approval after every three years of the project in accordance with the Rules 13 (2) (b), 15 (4) and 20 of the Environmental Assessment Rules 2021.
- x) Any change in the approved project shall be communicated to EPA, Khyber Pakhtunkhwa and shall be commenced after obtaining the approval.
- y) This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
- z) This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
- aa) There shall be no legal case pending in the courts against the project.

Accepted
24/11/202
 DIRECTOR (MALAKAND)

Copy for information to the;

1. Secretary Forestry, Environment & Wildlife Department, Govt. of Khyber Pakhtunkhwa
2. Director General EPA Govt. of Khyber Pakhtunkhwa Peshawar.
3. Deputy Commissioner, Dir Lower.