



**DIRECTORATE OF
ENVIRONMENTAL PROTECTION
AGENCY SWAT**

**FORESTRY, ENVIRONMENT & WILDLIFE
DEPARTMENT GOVT. OF KHYBER
PAKHTUNKHWA**

No. EPA/DS/NOCs/P.P/001-02

Date. 08/05/2019



To

The Deputy Commissioner,
Malakand.

Subject:

**ISSUANCE NO OBJECTION CERTIFICATE FOR INSTALLATION OF
"GOPL" PETROL PUMP/RETAIL OUTLET LOCATED ON PLOT
DOCUMENT REGISTERED NO.213 BHAI NO.01, VOLUME NO.26, PAGE
NO.319 TO 321, DATED 22.11.2018, ON MAIN MALAKAND-SWAT ROAD,
(N-95), AT VILLAGE THANA TEHSIL THANA BAIZAI SUB DIVISION
BATKHELA, DISTRICT MALAKAND.**

I am directed to refer to your letter No. 6159-65/ALC/DC-Mkd dated: 28/03/2019 on the above noted subject and to convey you environmental clearance for the installation of **GAS AND OIL PAKISTAN Ltd.** in the name of **SHADMAN PETROLEUM SERVICES**, only Petrol pump subject to the following conditions:

1. Construction/ physical works shall be started as per approved design from concerned departments.
2. The Safety measures as specified in Petroleum Rules as well as proposed by Director General (Petroleum) must be properly implemented.
3. Entry in to and exit route from the station shall be metallic and must not hamper the traffic movement in front of the station.
4. A proper drainage system shall be provided from the Filling Station & used lube oil in the jet wash shall be properly disposed off/ recycled.
5. Two rest / wash rooms (Male & Female) should be provided at the Station.
6. Prayer area shall be designated in the filling station to facilitate the public.
7. Precautionary sign board and environmental messages must be mounted at appropriate sites.
8. Service Station is not allowed within the premises of Filling Station.
9. Trees of ornamental nature should be planted in and around the proposed petrol pump and shall take-care of the same.
10. Construct the 4FR (Fire and Shock Resistant) wall minimum of 12 feet height towards the house and also install the underground tanks away from the house.

Environmental Protection Agency reserves the right to check and to ensure the implementation of pollution control measures at the project area. Moreover, in case of non compliance with any of the above mentioned conditions, this approval will be considered Null and void.

Director (Malakand)

Copy for Information:

PA to Director General, EPA, Govt of Khyber Pakhtunkhwa.