

SCHEDULE-VIII
Decision on IEE

- 1 Name, address of proponent:** Mr. Gohar Ali (Owner),
Near Wali Interchange Toru Road, Daftari
Kalay, District Mardan.
Contact No. 0306570000
- 2. Description of project.** M/S Gohar Ali Afridi International
Petroleum Gas Pvt Ltd is going to be
installed near Wali Interchange Toru Road,
Daftari Kilay, District Mardan, Khyber
Pakhtunkhwa for the purpose to establish
LPG Storage & Bottling Plant. One tank
having capacity of 60 MT will be installed.
Total cost of the project is Rs. 60 million.
Total area of the project is 16 kanal. Filling
capacity of the plant is 30 MT/day. Source
of energy will be WAPDA 50 KVA and
Generator. Total 22 number of staff will
work at the said plant. Water requirements
for construction phase will be 2000
gal/day while during operational phase
will be 8000 gal/day.
- 3. Location of Project.** The Project is located in District Mardan

GPS Coordinates:

Corner 01: 34.11247 N, 72.08526 E


Corner 02: 34.11320 N, 72.08533 E

Corner 03: 34.11318 N, 72.08641 E


Corner 04: 34.11243 N, 72.08636 E

Storage Tank 34 06 45.87 N, 72 05 09.37 E

34 06 45.65 N, 72 05 08.77 E


DIRECTOR
Environmental Protection Agency
Govt. of Khyber Pakhtunkhwa
Peshawar

GIS Map




4. **Date of filing of IEE.**

23/08/2022

(Ref. EPA Diary No. 132)

5. In light of visit report dated 02/08/2022 carried out by the team of EPA subsequent GIS Mapping and after a careful review of IEE report, this Agency has decided to accord construction phase Environmental Approval of the Initial Environmental Examination (IEE) Report of **“M/S Gohar Ali Afridi International Petroleum Gas Pvt Ltd”** located near Wali Interchange Toru Road, Daftari Kilay, District Mardan, as per the Khyber Pakhtunkhwa Environmental Protection Act, 2014 and Khyber Pakhtunkhwa Environmental Assessment Rules-2021 subject to the following terms & conditions:-

- a) The proponent shall adopt all precautionary and mitigation measures identified in IEE Report, explanation/clarification submitted to this Agency in response to various observations/queries raised during presentation as well as any un-anticipated impacts during the construction and operation phase of the project.
- b) The Proponent shall ensure the compliance and implementation of the National Environmental Quality Standard (NEQS) for ambient air, noise, water and gaseous emission during construction phase of the Project.
- c) All the construction and installation in the project area must be carried out according to Site Plan and instructions provided in NFPA 58 and OGRA Rules 2001, (Amended 2014) specially regarding the distance from the


DIRECTOR
Environmental Protection Agency
Govt: of Khyber Pakhtunkhwa
Peshawar

- d) The safety and emergency measures shall be carried out in the premises of the project area e.g. emergency exits, fire extinguisher as per OGRA Rules 2001 (amended 2014).
- e) The proponent shall take sufficient security arrangements.
- f) Personal protective equipment shall be provided to all workers to ensure health and safety with first aid box for emergency medical coverage.
- g) Proper diking shall be carried out around the storage tanks.
- h) Vehicle carrying LPG shall be properly labeled with the message indicating existence of LPG, etc.
- i) The access road shall be extended upto the maximum width to avoid traffic congestion.
- j) The vehicles shall be parked in designated parking area inside the plant.
- k) Awareness messages shall be mounted in and outside of the storage.
- l) Solid waste/Dcbris/Excavated material shall be disposed off at designated site with the prior permission of respective authority (i.e. TMA, etc.)
- m) Washroom shall be provided at the storage area.
- n) Plantation along the boundary wall and in open space shall be carried out.
- o) Grasses and vegetation around the storage tank is potential source of ignition when dried. Therefore, the same shall be cleared and the area be concreted or tiled. Moreover, impounding concrete flooring along with underground storage Tank shall be carried out around storage Tanks.
- p) Soap testing of all joints and pipes shall be carried out regularly to check the leakage and take appropriate mitigation measures.
- q) Advance fire extinguishing system shall be installed in the unit.
- r) The monitoring team of this Agency shall regularly visit the Project site to check the terms and conditions of the approval and compliance of the Khyber Pakhtunkhwa Environmental Protection Act, 2014.
- s) Non-technical jobs shall be provided to the local people of the project area.
- t) The proponent shall provide the copy of this approval and IEE Report to the contractor for information and compliance.
- u) The storage tank shall be installed at the minimum distance of 100m from the residential area.

6. The proponent shall be liable for correctness and validity of the information provided in the environmental report.

7. The proponent shall be liable for compliance of Regulations 14, 15, 18, 19 and 20 of Khyber Pakhtunkhwa Environmental Assessment Rules-2021, regarding approval, confirmation of compliance, entry, inspections and monitoring.

8. The proponent shall comply with the Rule- 14 (2) of the Khyber Pakhtunkhwa Environmental Assessment Rules-2021 and shall submit undertaking on stamp paper for the compliance of conditions mentioned in Environmental Approval.
9. This approval is accorded only for the construction phase of the project. The proponent will obtain approval for operation of the project in accordance with the Rule 15 (1) of Khyber Pakhtunkhwa Environmental Assessment Rules-2021.
10. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
11. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
12. There shall be no legal case pending in the courts against the project
13. In exercise of the power under Section 13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the IEE Report of “M/S Gohar Ali Afridi International Petroleum Gas Pvt Ltd” with above mentioned terms and conditions.


Dated: Peshawar 01/11/2022

Tracking/File. No. EPA/IEE/LPG/Gohar Ali/2022/383-85

Tracking Code:



<https://epakp.gov.pk/environmental-approvals/>


DIRECTOR (CENTRE)
CENTRAL DIRECTORATE
ENVIRONMENTAL PROTECTION AGENCY,
GOVT. OF KHYBER PAKHTUNKHWA,
2nd FLOOR, KHYBER PAKHTUNKHWA BAR
COUNCIL BUILDING, KHYBER ROAD
PESHAWAR CANTT.

DIRECTOR
Environmental Protection Agency
Govt. of Khyber Pakhtunkhwa
Peshawar
01/11/2022