



OFFICE OF THE DIRECTOR (SOUTH)  
ENVIRONMENTAL PROTECTION AGENCY (EPA)  
GOVT. OF KHYBER PAKHTUNKHWA

House # 285, Opp: Panyala House, Arif Abad, Diyal Road, District D.I.Khan  
Phone No. 0966-740171.



No: EPA/SD/DIK/GEA/Filling Station/Hassan F.S/DIK

9955-56

Dated 18, 11 2022

To,

Haji Muhammad Khalil Masood,  
**M/S Hassan Filling Station (PSO),**  
Near Police Check Post, Draban Road, District D.I.Khan  
Cell #: 0332-9383177

Subject: **OPERATIONAL ENVIRONMENTAL APPROVAL OF HASSAN FILLING STATION (PSO), NEAR POLICE CHECK POST, DRABAN ROAD, DISTRICT D.I.KHAN.**

Reference to your application No. Nil dated 26.10.2022 and followed by Administrative Penalty Imposed by this Agency dated 31.10.2022 along with NOC of Deputy Commissioner office D.I.Khan and field visit report dated 23.08.2022. It is stated that this Agency allows you to operate your Pump Located Near Police Check Post, Draban Road District Dera Ismail Khan (GPS N:31.8243 E:70.8529, N:31.8247 E:70.853, N:31.8242 E:70.8526, N:31.8246 E:70.8524) with following terms & conditions / Mitigation Measures;

1. All construction and installation in the project area shall be carried out according to master plan.
2. The safety measures as specified in petroleum Rules & SNGPL Rules/ Law shall be implemented within the premises of the project area.
3. Personal Protective Equipments must be provided to all workers during the working hours.
4. Precautionary sign board and Environmental messages must be mounted at appropriate sites.
5. Entry in to and exit routes from the station shall be metallic and must not hamper the traffic movement in front of the station.
6. A proper drainage system shall be provided from the Filling Station and used lube oil in the jet wash shall be properly disposed of /recycled.
7. Washrooms will be constructed at the Filling Station two washrooms must be allocated for Female use.
8. All the washrooms must be cleaned on daily basis.
9. Service station is not allowed within the premises of Filling Station, in case of installation/construction separate approval must be obtained from this Agency.
10. Plantation of 30 plants such as Pine, dates, jamun, and Sheshum. etc., must be carried out within the premises of the Filling Station and shall take-care of the same.
11. Grasses and vegetation around the storage tank is potential source of Ignition. It shall be cleared and the area shall be concreted or tiled.
12. Solid waste of the project must be collected on daily basis and properly dispose of at the TMA dumping site/Ground.
13. The proponent shall provide non-technical jobs to the people of surrounding villages of the project.
14. Clearly mark entrance and exit routes and place fire safety signage at different places.



OFFICE OF THE DIRECTOR (SOUTH)  
ENVIRONMENTAL PROTECTION AGENCY (EPA)

GOVT. OF KHYBER PAKHTUNKHWA

House # 285, Opp: Panyala House, Arif Abad, Diyal Road, District D.I.Khan  
Phone No. 0966-740171.



No: EPA/SD/DIK/GEA/Filling Station/Hassan F.S/DIK

9955-56

Dated 18, 11, 2022

15. All the emissions/effluents/Noise (if any) shall be kept within permissible limits of National Environmental Quality standards (NEQS).
16. EPA monitoring team will regularly visit the project site and suggest further measures for the improvement of environment.
17. The proponent shall be responsible to facilitate the EPA team during visit/inspection/monitoring.
18. Avoid discharging of wastewater in the open land/ Nallah/Road/Stream/ and construct soakage pits for wastewater in the premises of the project area.
19. In case of extension/ change of design, prior approval shall be obtained from this office.
20. Avoid installation of Generator within the premises of the filling station. However, if needed; install silence generator with canopy to control noise pollution.
21. The proponent is bound to obtain NOC/License from NHA, Industry department and DPO & DC office before starting the operation in case of failure the approval will be considered null & void.
22. In case of any public complaint or court case received against your Filling Station, this Agency has reserved the right to issue Show Cause Notice and Suspend/Cancel this Approval.
23. The owner will strictly follow the above mentioned terms & conditions during operation.
24. An affidavit/undertaking must be submitted to this Agency within one week regarding compliance of above mentioned conditions, in case of failure the approval will be considered null & void.

This approval shall be treated as null and void if all or any of the mitigations mentioned above is/are not complied. Furthermore, the unit will be regularly monitored and in case of violation, legal action will be initiated under Khyber Pakhtunkhwa Environmental Protection Act-2014.

  
DIRECTOR (SOUTH)  
EPA, SOUTHERN DIRECTORATE  
DERA ISMAIL KHAN

DIRECTOR  
Environmental Protection Agency  
Southern Region, D.I.Khan  
Govt. of Khyber Pakhtunkhwa

Copy for information to the:

- Deputy Commissioner D.I.Khan.