

SCHEDULE-IX
Decision on GEA

1. **Name, address of proponent:** Mr. Bakhtiyar Khan S/o Rawail Gul,
M/S Madina Petroleum (GOPL),
Mailing Address: Main Shabqadar
Road, Mouza Bunyadi at Mouza Essa Khel
Hameed, Tehsil Shah Alam, District
Peshawar


2. **Description of project:** The Proposed Filling Station is located at **Main Shabqadar Road, Mouza Bunyadi at Mouza Essa Khel Hameed, Tehsil Shah Alam, District Peshawar, Khyber Pakhtunkhwa**. The total area of the project site is 21507.75 SFT. The project features involves, filling shed area, underground storage tanks area, mosque, offices area, green belt, toilet area etc. the project will have 03 underground storage tanks with a total storage capacity of MS (23750 ltrs) HOBC (23750 ltrs) HSD (50000 ltrs). There will be 02 units (04 points) for MS, 01 Unit (02 points) for HOBC and 02 units (04 points) for HSD. The source of energy will be WAPDA.

3. **Location of project:** The project is located in District Peshawar.

4. **GPS Coordinates & Map:**

S#	Latitude	Longitude
1	34.1422	71.605
2	34.1427	71.605
3	34.1427	71.6053
4	34.1424	71.6054
5	34.1422	71.6054

Handwritten signature and initials in blue ink.



5. **Date of filing of GEA**

02/06/2023 (Ref: EPA Diary No.909)

6. After careful review, the Central Directorate, Environmental Protection Agency, Govt. of Khyber Pakhtunkhwa has decided to accord approval of the GEA Report for **“M/S Madina Petroleum (GOPL), Main Shabqadar Road, Mouza Bunyadi at Mouza Essa Khel Hameed, Tehsil Shah Alam, District Peshawar”** for **Construction Phase**, in line with the Khyber Pakhtunkhwa Environmental Protection Act, 2014 and Khyber Pakhtunkhwa Environmental Assessment Rules, 2021, subject to the following terms & conditions:-

- a) The proponent shall adopt all precautionary and mitigation measures recommended in the GEA Report submitted to this Agency and any un-anticipated impacts arising during the Construction & Operation phase of the project.
- b) The proponent shall ensure the compliance and implementation of the National Environmental Quality Standards (NEQS) for noise, waste water and gaseous emission during construction & operation phase of the project.
- c) The safety and emergency measures as per Petroleum Rules shall be carried out in the premises of the project e.g. emergency exit and fire extinguishers etc.
- d) Grasses and vegetation around the storage tank is potential source of ignition. It must be cleared and the area shall be concreted or tiled.
- e) Personnel protective equipment's (PPEs) shall be provided to the workers during working hours. Furthermore, the proponent shall also ensure efficient health & safety measures for the protection of workers and passers backed by a comprehensive emergency response plan, e.g. helmets, signboards and shoes etc.
- f) Entry and exit route from the site shall be metallic and must not hamper the traffic movements in the front of filling station.
- g) Plantation shall be carried out according to submitted plantation plan.
- h) In case of power shut down, a properly fixe GENSET (if used) shall be installed in a sound/tremor barring and absorbing cabin having at least 10 feet high duct/stack to reduce noise, vibration, smoke and shall comply with the NEQS.
- i) Separate prior approval shall be obtain from this Agency for Vehicle Service Station as per Khyber Pakhtunkhwa Environmental Assessment Rules, 2021.
- j) Safety of the social & cultural life of the local community shall be ensured.
- k) The proponent must ensure to avoid dumping of debris unattended. The same shall be reused in construction activity of the proposed project or a proper area should be identified for disposal of debris.
- l) Avoid direct discharge of waste water into the channel.
- m) Skilled/unskilled jobs must be offered to the local community first and if not available locally then the same may be hired from other areas.
- n) All conflicting issues regarding compensation, lease agreement etc. to be settled and a certificate in this regard should be submitted to EPA.
- o) If any issues come up during execution of the project the proponent shall be made bound to address those issues which are unforeseen and not identified in the submitted GEA Report.
- p) The monitoring team of EPA will visit the project site to check the terms and conditions of the approval and compliance of the Khyber Pakhtunkhwa

Environmental Protection Act, 2014. Furthermore, the management of the project shall facilitate the EPA monitoring team at the time of monitoring.

- q) The proponent shall provide the copy of this approval and the GEA Report to the contractor for information and compliance.
 - r) There shall be nothing repugnant to any Govt. order or policy on subject.
 - s) The proponent shall be liable for correctness and validity of the information provided in the GEA report.
7. The proponent shall be liable for compliance of Rule 14, 15, 17, 18 and 19 of the Rules, 2021.
 8. This approval is accorded only for the **Construction Phase** of the project.
 9. The proponent must obtain separate approval for operation of the project in accordance with the Rule 15 (1), Assessment rules 2021.
 10. The proponent shall comply with the rule-14 (2) of the rules, 2021 and shall submit undertaking on stamp paper for compliance of the conditions of approval.
 11. Any change in the approved project shall be communicated to EPA, Khyber Pakhtunkhwa and shall be commenced after obtaining the approval.
 12. This approval shall be treated as Null and Void, if all or any of the conditions mentioned above is/are not complied with:
 13. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
 14. There shall be no legal case pending in the courts against the project
 15. In exercise of the power under Section 13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the GEA Report for construction phase of the aforementioned project with the terms and conditions as mentioned.

Dated: Peshawar 21/06 /2023

Tracking/File.No. EPA/CD/GEA/Petrol-pumps/Madina/Pesh/23/147-49

Tracking Code:



Handwritten initials

Handwritten signature
Director (Center) 21/06/2023
Environmental Protection Agency
Central Directorate
2nd Floor Bar Council Building
Khyber Road Peshawar Cantt.