

SCHEDULE-VIII

Decision on IEE

1. **Name & address of Proponent:** Mr. Asher Navaid (GM Work),
M/S Fauji Cement/Askari
Cement Pvt Ltd,
Mailing Address. Fauji Cement
Near village Kahi, Nizampur,
District Nowshera
2. **Description of Project:** "The proposed project for which Initial
Environmental Examination (IEE) is
being conducted is a proposed project
of 05 MW Solar Plant extension, which
is already approved 11.25 MW Solar
power Plant by M/S Fauji Cement Pvt
Limited located at village Kahi,
Nizampur District Nowshera. The
power plant will supply electricity to
Fauji Cement Company Limited to
make them able to meet their energy
demand for regular operations. The
land area required for installation of
05 MW solar power plant will be 14
Acre. The proposed project will reduce
the emission of gases/GHG footprint
of cement industry operations. In the
Proposed project total 8547 number of
Photocells of 550 watt per plate will be
installed. The Initial Environmental
Examination of the proposed project
has identified potential impacts that
will likely to arise during the
construction and operational phase of
the project. To minimize the effects of
the adverse impacts of the proposed
project, the IEE has recommended
mitigation measures. An
Environmental Management Plan has
also been prepared, which defines the
institutional arrangements required
for its implementation.
The Project site is located at Village
Kahi, Nizampur, District Nowshera.
3. **Location of Project:**

2014 and Khyber Pakhtunkhwa Environmental Assessment Rules, 2021
subject to the following terms and conditions:

- a) The proponent shall adopt all precautionary and mitigation measures reflected in the submitted IEE Report as well as replies of the proponent submitted to this Agency and any un-anticipated impacts arising during the construction and operation phase of the project.
 - b) The proponent shall ensure the compliance and implementation of National Environmental Quality Standards (NEQs) for ambient air, noise, water and gaseous emission during the construction and operational phase of the project.
 - c) This Environmental Approval is issued only for the Installation of Proposed Extension of 11.25 MW Solar Plant to 16.25 MW Solar Power Plant.
 - d) The proponent shall obtain separate Environmental Approval for transmission line and grid station.
 - e) Any other connected activity with the installation of proposed extension of solar plant must take separate Environmental Approval according to the Khyber Pakhtunkhwa Environmental Protection Act-2014.
 - f) The proponent shall provide the copy of this approval and IEE report to the contractor for information and compliance.
 - g) Proper disposal mechanism shall be adopted for expired batteries, panels and other electronic wastes.
 - h) Proper mechanism shall be designed for collection, recycling and re-use of waste water.
 - i) Approval from Power and Energy Department and WAPDA for metering/transmitting activities etc. shall be taken (if required).
 - j) The proponent shall ensure the implementation of health and safety measures for the protection of workers. For operation activities, job safety analysis plan shall be submitted to this Agency prior to operation of the project.
 - k) Plantation of Chinara and Deodar trees must be carried out in the available area of the factory.
 - l) Non-technical jobs must be provided to local community.
 - m) No extension would be permitted in the future in the existing project without prior approval of the EPA/Govt. of Khyber Pakhtunkhwa.
 - n) The proponent is bound to implement any additional measures for the protection of Environment as and when suggested by EPA.
 - o) Environment related messages shall be mounted in and outside of the project area.
 - p) Sign boards must be installed on the sensitive area for guidance of the workers as well the visitors.
7. The proponent shall be liable for correctness and validity of the information supplied by the environmental consultant.
 8. The proponent shall be liable for compliance of 14, 15, 18, 19 and 20 of Khyber Pakhtunkhwa Environmental Assessment Rules, 2021,




- regarding approval, confirmation of compliance, entry, inspections and monitoring.
9. This approval is accorded only for the installation/ construction phase of the project. The proponent will obtain approval for operation of the project in accordance with the Rule 15 (1) of Khyber Pakhtunkhwa Environmental Assessment, Rule 2021.
 10. Any change in the approved project shall be communicated to EPA, Khyber Pakhtunkhwa and shall be commenced after obtaining the approval.
 11. This approval shall be treated as null and void if all or any of the conditions mentioned above is/are not complied with.
 12. This approval does not absolve the proponent of the duty to obtain any other approval or clearance that may be required under any law in force.
 13. There is no legal case pending in the courts against the project.
 14. In exercise of the power under Section 13 of the Khyber Pakhtunkhwa Environmental Protection Act, 2014, the undersigned is pleased to approve the IEE Report for "**Construction Phase**" of the project with above mentioned terms and conditions.

Dated: Peshawar 22/08/2024
Tracking/File.No. EPA/CD/IEE/05 MW/Solar-Plant/Fauji-Cement/Now/24/1330-32

Tracking Code:



<https://epakp.gov.pk/environmental-approvals/>


DIRECTOR CENTRE,
EPA, Khyber Pakhtunkhwa,
2nd Floor, Khyber Pakhtunkhwa
Bar Council Building, Khyber Road,
Peshawar Cantt.